# ift-Nachweis

# ift

## **Classification Report**

Number 20-001378-PR02 (NW-A01-02-en-01)

Owner Europa Profil Aluminio S.A.

56th Klm National Highway

Athens - Lamia 32011 Innofita Viotas

Greece

Product Double tilt and turn casement door with central opening

meeting stile

Designation System: EUROPA EOS 60

Shipping name: EUROPA EOS 60 DOUBLE SASH

Details Manufacturer Europa Profil Aluminio S.A., - Innofita Viotas;

Material Aluminium system with thermal break; Type of opening Turn/ tilt-turn window; Opening direction Active casement DIN right (opening) to the inside, Inactive casement DIN left (opening) to the inside; Overall dimensions (W x H) 1600 mm x

2200 mm

Special features Test sequence. Material compatibility must be taken into

account. Material durability must be taken into account. The strength, durability and material compatibility of the adhesive system was not part of the test and is tested sep-

arately.

Result

Air permeability according to EN 12207:2016-12

© ift Resumberin

Class: 4

Resistance to wind load according to EN 12210:2016-03

Carl Mindress of M

Class: C4/B4

Watertightness according to EN 12208:1999-11

in Rosenhim

**Class: E750** 

ift Rosenheim 21.04.2020



Dimitrios Moustakidis, MSc, Dipl.-Ing. Operating Testing Officer Building Component Testing

### Basis \*)

EN 14351-1:2006+A2:2016-09
\*) and corresponding national versions
(e.g. DIN EN)

Test report: 20-001378-PR02 PB-A01-02-en-01

### Representation



### Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

### Validity

There is no time limit.

When using this document the upto-dateness of above basis and the conformity of the product have to be observed.

### Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft ID: CD3-46AD4



