

Classification Report

Number	20-000989-PR01 (NW-A01-0203-en-02)
Owner	Europa Profil Aluminium S.A. 56th Klm National Highway Athens - Lamia 32011 Innofita Viotas Greece
Product	Sliding door
Designation	System: EUROPA ESS 34 Shipping name: EUROPA ESS 34 DOUBLE SLIDING
Details	Manufacturer Europa Profil Aluminium S.A., - Innofita Viotas; Material Aluminium system with thermal break; Type of opening Lifting sliding; Opening direction Sash right before sash left; Overall dimensions (W x H) 1600 mm x 2200 mm
Special features	Test sequence. Increased operating forces. The vapour pressure equalisation of the glazing rebate has to be ensured. Material compatibility must be taken into account. Material durability must be taken into account. Construction with visible internal drainage. The strength, durability and material compatibility of the adhesive system was not part of the test and is tested separately.

Result

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C1/B1

Watertightness according to EN 12208:1999-11



Class: 6A

ift Rosenheim
30.03.2020



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
(e.g. DIN EN)

Test report: 20-000989-PR01 PB-
A01-0203-en-02

Replaces ift-Nachweis:

20-000989-PR01 NW-A01-0203-
en-01 dated 10.03.2020.

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: F38-08CA0